

Guidance for Clients

- The Fire Precautions adopted in any building or business undertaking must be established by a Fire Risk Assessment. A Fire Risk Assessment is a legal requirement for virtually all non-domestic premises, and for certain multiple-occupancy dwellings and parts of such dwellings.
- All staff should be trained in the action to take in the event of a fire. Every opportunity should be taken to instruct personnel in the use of extinguishers, and to demonstrate their performance. Extinguishers for different fire classifications will have different training requirements. Attention is drawn to the legal obligations concerning training for the use of fire extinguishers.
- The position and type of a fire extinguisher should be indicated on a sign so that, if the extinguisher is removed, this can be identified during a safety inspection, and a replacement ordered. Wherever practicable, extinguishers should be clearly visible. Where this is not possible, the extinguisher should be indicated by location signs.
- Apart from the nonconforming extinguishers recorded, all portable fire extinguishers have been inspected and serviced in accordance with BS5306-3. Clients are reminded of the recommendations in BS5306-3 for routine weekly inspection. It is recommended that regular inspection of all extinguishers, spare gas cartridges and replacement charges should be carried out by the user or user's representative at regular intervals to make sure appliances are in their proper position and have not been discharged, or lost pressure, or suffered obvious damage. The user should replace extinguishers not available for use by serviceable extinguishers.

PLEASE NOTE: H E WOOLLEY LIMITED CAN HELP CLIENTS FULFIL THE ABOVE REQUIREMENTS.

General Terms and Conditions

The Goods and Services supplied by H E Woolley Limited are provided under the Company's Terms and Conditions, copies of which can be provided on request. The title of the Goods shall not pass to the Buyer until payment has been made in full.