

Diocese of Leicester: Register of Cases since 1 January 2000: Packington - Prestwold

Ben No: Church

20206 Packington, Holy Rood

Case No: L122/2000

Installation of Sound Reinforcement and Induction Loop System

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That the speakers and cable should colour match the background as closely as possible

Case No: L084/2002

Provision of new copper roof to north side of Nave

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L063/2003

1. Roof repairs to north side of Nave, South Aisle and south Nave (copper)
2. Replacement of broken slates on north aisle roof and replacement of window grilles on Chancel east window
as detailed in the Quinquennial Inspection Report

DAC Certificate Conditions: -

1. A time limit of 12 months

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Case No: L002/2004

1. To clean and repair a 'Ten Commandments Board' as per the condition report from Dian Hall Conservation dated July 2003
2. To re-hang the Board in its original position on existing brackets in the south aisle of the church.

DAC Certificate Conditions: -

1. A time limit of 12 months
2. The Conservator's Report to be amended in line with the email dated 28 May 2004.

Case No: L120/2005

1. Remove 6 tubular heaters at high level in the Nave
2. Replace existing lights in the Chancel, Nave and side Aisles with modern metal halide lighting

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That the PCC considers lighting the ceiling of the church as well to give a balanced appearance
3. That the discharge units are fitted with Warm White 3000K lamps
4. That the new fittings in the nave should be aligned with the apex of each archway rather off centre,

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued 16/11/2004

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued 18/10/2005

Case No: L165/2008

Installation of Linquartz heaters: -
1. 2 x 3kW heaters in the meeting room
2. 1 x 3kW heater in the Choir Vestry

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That, where possible, all fixings should be made into joints, not stonework, using stainless steel or non-ferrous screws in fibre plugs

Case No: L067/2009

Extension to the existing Garden of Remembrance

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued 26/11/2008

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued 02/06/2009

Case No: L118/2010

Following the 2008 Quinquennial Inspection: -

1. Repairs to the Tower parapet
2. Replacement of the east Chancel gable cross
3. Re-pointing of south Clerestory

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No: L113/2011

Repairs to the North Aisle roof comprising: -

1. Repairs to 25 splits
2. Securing of 1.1m of flashing joint
3. Installaing short sections of cover flashing over 3 existing splits

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That all lead work must take place under a "Hot Work" Permit

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 29/09/2010

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No: L178/2012

Replacement of the east Chancel gable cross

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No: L169/2012

1. Re-fixing of cill and flashing to east clerestory window of South Aisle
2. Re-dressing the insitu cills and re-fixing the flashings to three remaining south clerestory windows

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Case No: L171/2015

Installation of second down-conductor as recommended by the Lightning Protection Engineer

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That, where possible, all fixings should be made into joints, not stonework, using stainless steel or non-ferrous screws in fibre plugs

Case No: L067/2015

1. Re-modelling of WC
2. Installation of Servery in the existing Vestry
3. Alterations to South Porch to give level access

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. That no works shall take place until the PCC, after consultation with the Diocesan Archaeological Adviser, has secured the implementation of a programme of archaeological works in accordance with a written scheme of investigation which has been submitted by the PCC and approved by the DAC

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

15/11/2018

Case No:

Felling of 4 Trees in the churchyard

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No:

Replacement of Sound System

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. If it is decided to amplify any part of a service, the PCC must install an assistive hearing system to comply with the requirements of the Equality Act 2010 (formerly known as the DDA). This assistive hearing system can be either a conventional AFILS (Audio Frequency Induction Loop System) or the

Case No:

Installation of Roof Alarm

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 2. That an updated Electrical Condition Report is commissioned, and submitted to the DAC Secretary, after the installation
- 3. That the cables must be MICC/FP200 or equivalent

Case No:

Felling of Lime Tree (no.17)

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No:

1. Extending of churchyard path and installing bench in churchyard
 2. Replacing wooden gates to burial ground

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
 2. That the postholes for gates and the excavation for the concrete base for the bench should be hand dug
 3. That Human Remains should be expected when excavating within a churchyard. Any remains should

Case No:

Removal of damaged branches from 2 Pine Trees

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
 2. That the PCC ensures that Conservation Area Consent is obtained from Northwest Leicestershire District Council for the works

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued 14/01/2021

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued

Case No:

1. Felling of 2 Pine Trees
 2. Works to 8 other Trees in the churchyard

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
 2. That if evidence of bats is found during works, work should stop immediately and Natural England must be contacted on 0845 1300 228 or mailto:Jbarker@bats.org.uk for advice on the best way to proceed

Case No:

1. CONFIRMATORY APPLICATION for works undertaken with Interim Faculty: -
 a) Works to make safe the collapsed section of wall
 2. Re-building of the churchyard wall

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
 2. That an archaeological watching brief will be required on excavations and trenching for the wall foundations. Check stone for signs of re-use (see below). This should be carried out by a professional contractor who is a member of the ClfA, or who is employed by a ClfA Registered Organisation. No

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?

Date Faculty Issued 11/03/2021

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?

Date Faculty Issued

Ben No: Church

20311 Peatling Magna, All Saints

Case No: L085/2008

Installation of under pew heaters

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That the heaters be fitted with appropriate guards
4. That all wiring should be as unobtrusive as possible and of an appropriate colour to blend with the

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 10/12/2008

Case No: L201/2009

Introduction of a display case for historical documents

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No: L234/2010

Repairs to leaking leadwork over the Nave

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That all lead work must take place under a "Hot Work" Permit
4. That if major repair works are required to addresses the damage caused by the ingress of water that

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Case No:

Re-covering of Nave roof

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 29/03/2019

Ben No: Church

20308 Peatling Parva, St Andrew

Case No: L/1999

Installation of Bench seat in churchyard

DAC Certificate Conditions: -

1. A time limit of 12 months

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 12/01/2000

Case No: L127/2004

Repair of stained glass and associated leadwork in a damaged lancet window on south elevation of the church

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That all leadwork be carried out under a "hot work" permit

Case No: L086/2004

- 1. Designation of an area of the churchyard as a "Garden of Remembrance" for the burial of ashes as shown in the attached photograph and plan
- 2. Marking of burials in the area designated with flat marker stones to the specification provided in the Diocesan guidelines

DAC Certificate Conditions: -

- 1. A time limit of 12 months

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued 13/01/2005

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued 04/11/2004

Case No: L116/2006

Removal of deadwood from Lime Tree

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L040/2007

Installation of Sound System

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That the PCC ensures the contractor complies with the DAC Conditions on the installation of Sound and Induction Loop Systems
3. That the PCC keeps the decision not to install an induction loop system under regular review and

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued 30/08/2007

Case No: L186/2009

Repairs to the Nave roof

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No: L170/2010

1. Refurbishment, re-tuning and re-hanging of existing Bells
2. Installation of new treble Bell

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That the inscription for the new bell should be agreed by the Archdeacon.

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 08/02/2010

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 25/01/2011

Case No: L014/2014

Following the 2013 QI Report, Repairs to: -

1. South Aisle
2. Nave
3. North Aisle
4. Chancel
5. Boundary Walls

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. That a set of record photographs be taken prior to the commencement of the works and after the works as a monitor, particularly if cracks re-appear, which should be submitted to the DAC Secretary
3. That no stonework or pointing is undertaken if the weather is frosty and that protection be put in

Case No: L008/2014

Conversion of Clock to autowinding

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 13/03/2015

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 26/03/2014

Case No:

Repair to Aisle roof

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 27/11/2018

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. That the work should be carried out at the direction of the church architect

Ben No: Church

20513 Peckleton, St Mary Magdalene

Case No: L044/2000

- 1. General repairs to stonework, rainwater goods, roofs, etc following Quinquennial Inspection
- 2. Retrospective permission for renewal of temporary Chancel flooring

DAC Certificate Conditions: -

- 1. A time limit of 12 months

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 16/07/2001

Case No: L123/2001

Restoration of Porritt Organ

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L090/2001

Installation of car park lighting and floodlighting

DAC Certificate Conditions: -

1. A time limit of 12 months

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 06/02/2002

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 22/02/2002

Case No: L043/2002

Refurbishment of car park adjacent to churchyard

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L150/2006

1. Repair to east window following vandalism
2. Installation of window protection cut to fit the mullions and fixed to joints
3. Re-location of WW1 wooden cross from stone cross on grave on n side of the church to inside the church

DAC Certificate Conditions: -

1. A time limit of 12 months

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 08/12/2006

Case No: L041/2007

To replace outer North and South Porch doors

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That the PCC installs matching door furniture on the outside of the doors to relieve the uniform appearance

Case No: L190/2007

Repairs to the metal railings

DAC Certificate Conditions: -

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?

Date Faculty Issued 06/06/2007

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?

Date Faculty Issued

Case No: L004/2008

Repairs to the chest tomb of Henry Bickley (d. 1869)

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L146/2008

1. Re-pointing of the: -
 - a) North Chancel
 - b) Nave
 - c) Porch walls
2. Creation of footpath from the car park to the North Door

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That the surface of the path should be either paving slabs or resin-bonded gravel
4. That the Church Architect must approve a sample of re-pointing

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 28/02/2008

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 09/10/2008

Case No: L007/2008

Re-pointing of north: -

1. Chancel wall
2. Nave wall
3. Porch

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L062/2009

Re-decoration of the church

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. That only the paint specified by the Church Architect is used

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No: L001/2013

Planting of 1 Oak Tree

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That the PCC monitors the growth of the Oak Tree to ensure that it does not damage the memorials or the surface of the car park

Case No: L002/2013

1. Replacement of 15 x existing wall mounted Heaters with Dimplex QXD radiant type with gold tubes
2. Replacement of 2 x existing Dimplex AC3N over door air curtain heaters

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That the new electric Dimplex Quartz heaters should be fitted with "Gold" tubes
4. That any new wiring should be carried out using "FP200" cable or similar approved

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No: L115/2014

Installation of Sound and Induction Loop System to Nave and Chancel

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 3. That the PCC ensures the contractor complies with the DAC Conditions on the installation of Sound and Induction Loop Systems (attached)

Case No: L233/2015

Installation of: -

- 1. Accessible WC
- 2. Severy

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No:

Re-location of Heaters

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 2. That all wiring should be as unobtrusive as possible and of an appropriate colour to blend with the background and to be "FP200" cable or similar approved
- 3. That, where possible, all fixings should be made into joints, not stonework, using stainless steel or

Case No:

- 1. Large Yew to front of church - Raise canopy to give a clearance from ground level of 2.4m
- 2. 17no Golden Irish Yew - Reduce height to 6ft
- 3. 17no Golden Irish Yew - Following the above works when suitable regenerative growth has established, cut the sides off the trees to re-establish the trees in a smaller form
- 4. English Oak at front corner of site - Raise canopy to give a clearance from ground level of 2.4m

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No:

1. Tower and Masonry Repairs comprising: -
 a) Re-fixing of all slate Tower louvres
 b) Re-fixing of loose merlons
 c) Stone repairs to Tower and base of Spire
 2. Improvements to internal Tower ladder access

Works are set out in 12864-DB3-B01-00-SP-A-00100 Spec Schedule of Works and Prelims-BOUND

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
 2. That any stonework to be replaced is carefully checked for tool marks and, if found, the stones are set aside and Diocesan Archaeological Adviser is notified
 3. That, where possible, all fixings should be made into joints, not stonework, using stainless steel or

Case No:

Drainage Works comprising: -
 a) Excavation of external church perimeter in conjunction with archaeological watching brief
 b) Installation of French drains, new gullies, extending rainwater pipes and improvements to rodding drains and associated work

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued 22/04/2020

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued

Case No:

Dig 4 trial holes to ascertain foundation depth + sample internal plaster

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 2. That no works shall take place until the PCC, after consultation with the Diocesan Archaeological Adviser, has secured the implementation of a programme of archaeological works in accordance with a written scheme of investigation which has been submitted by the PCC and approved by the DAC

Case No:

Felling of one dead tree

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued 10/06/2020

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued

Case No:

Trimming work on 3 Trees

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No:

Installation of a bench into the churchyard in memory of Ronnie Sowman

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Ben No: Church

10203 Pickwell, All Saints

Case No: L038/2001

- | |
|---|
| <ol style="list-style-type: none">1. Replacement of Rainwater Goods2. Provision of drains, gullies and soakaways |
|---|

DAC Certificate Conditions: -

- | |
|--|
| <ol style="list-style-type: none">1. A time limit of 12 months2. That the architect should liaise throughout with the Diocesan Archaeological Adviser |
|--|

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No: L042/2007

- 1. Removal of defective plaster and re-plastering of Aisles, Nave and Chancel
- 2. Re-decoration of the previously painted walls in the Tower, Aisles, Nave and Chancel

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That, in the event of wall paintings being discovered, the works stop immediately and the advise of the DAC is sought

Case No: L162/2007

Replacement of Rainwater Goods

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That, where possible, all fixings should be made into joints, not stonework, using stainless steel or non-ferrous screws in fibre plugs

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 18/04/2007

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No: L054/2007

Repairs to churchyard wall on Main Street

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That the works on site are to be monitored by Mr K J Hamilton, DAC Architect Member

Case No: L169/2007

- 1. Re-wiring of the church
- 2. New Lighting Scheme

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 3. That MICV (mineral insulated cables with a PVC/LSF sheath) or fire resistant cables such as Pirelli FP 200 GOLD should be used

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued 08/11/2007

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?
 Date Faculty Issued 18/01/2010

Case No: L184/2013

1. Installation of: -
a) Accessible WC in the base of the Tower with raised ringing chamber
b) Servery at west end of South Aisle
2. Upgrading of Heating System
3. Provision of disability access to the churchyard

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No: L153/2014

1. CONFIRMATORY APPLICATION for works undertaken: -
a) Phase 1 Re-pointing of the churchyard wall in 2011
2. Re-pointing of the churchyard wall and installation of weep holes

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. That a test panel of re-pointing be agreed by the Conservation Officer from Melton Borough Council
3. That any stone which is removed be checked for signs of re-use and, if need be, contact made with the Diocesan Archaeological Adviser

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Case No:

South Aisle masonry repairs

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No:

CONFIRMATORY APPLICATION for works undertaken: -

Replacement of North Aisle roof

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

10/12/2018

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

2. That the PCC submits an annual report detailing the state of the roof timbers (including moisture readings for the underboarding)

Case No:

Works to 3 Conifer Trees

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No:

Renovations to stonework of tomb

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Case No:

Stonefacing of a section of boundary wall to match the remainder of the boundary wall

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No:

Stonework repairs highlighted by the QI Report: -
1. On the south aisle, the top stone to the pinnacle second from the west, and the top three stones to the pinnacle second from the east should be re-dowelled and re-fixed, and the security of all of the stones to all four pinnacles should be checked carefully
2. The loose surface spalling stone and mortar over the south porch outer doorway should be carefully removed
3. A mason should check the security of the fixings to the Sharman monument on the exterior of the chancel south wall
4. The chest tomb near the chancel north wall should be fenced off and options for rebuilding should be considered – including approaching family descendants

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Ben No: Church

10201 Plungar, St Helen

Case No: L022/2002

Installation of Sound and Loop System

DAC Certificate Conditions: -

1. A time limit of 12 months

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No: L051/2005

Replacement of existing oil storage tank with a 2500 litre bunded plastic tank to comply with the Control of Pollution (Oil Storage) Regulations 2001

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L125/2005

Repairs to the east window of the Sanctuary

DAC Certificate Conditions: -

1. A time limit of 12 months

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 03/06/2005

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 29/11/2005

Case No: L096/2006

To make patch repairs to the plaster in the Porch

DAC Certificate Conditions: -

1. A time limit of 12 months

Case No: L021/2013

Re-covering of the Chancel roof

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That any plumbers marks found on existing lead should be photographed, identified and cut-out, then retained or spot-welded back into the new lead work according to the advice of the church architect

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
Minor Works Trees Faculty
Recommended Not Recommended No objections
Withdrawn
Faculty Issued?

Date Faculty Issued 24/10/2013

Case No:

Restoration and repair of church Clock

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 2. That an updated Electrical Condition Report is commissioned, and submitted to the DAC Secretary, after the installation
- 3. That, in line with the requirement and advice of the Ecclesiastical Insurance Group, the installation

Case No:

- 1. Re-covering of roofs: -
 - a) Nave
 - b) South Aisle
 - c) Organ Loft
 - d) Tower
 - e) Vestry
- 2. Replacement of the Tower roof structure and formation of an Access Hatch

DAC Certificate Conditions: -

- 1. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 2. That all remaining lead to be checked for the presence of plumbers' marks which must be recorded photographically, cut out and retained.
- Tower roof to be checked for the presence of plumbers' marks (1736 mark noted) which must be

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 29/06/2018

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 06/12/2021

Case No:

Re-covering of roofs:

1. Nave
2. South Aisle
3. Organ Loft
4. Tower
5. Vestry

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. That any plumbers marks found on existing lead should be photographed, identified and cut-out, then retained or spot-welded back into the new lead work according to the advice of the church architect
3. That the Tower roof is to be checked for the presence of plumbers' marks (1736 mark noted) which

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Ben No: Church

20402 Potters Marston, St Mary

Case No:

No Advice / Faculty / Informal Advice / Minor Works application has been made

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

DAC Certificate Conditions: -

1. A time limit of 12 months

Ben No: Church

20112 Prestwold, St Andrew

Case No: L/1999

Repairs to churchyard wall

DAC Certificate Conditions: -

1. A time limit of 12 months

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 04/05/2000

Case No: L058/2001 & L056/2003

- 1. Re-ordering of west end of church including removal and re-configuration of pews to front and rear of nave
- 2. Provision of kitchennette
- 3. Introduction of balcony above toilet and kitchen area with floor extended into the tower to provide a new ringing chamber
- 4. Glazed screen between ringing chamber and balcony
- 5. Installation of central heating

DAC Certificate Conditions: -

- 1. A time limit of 12 months 2. PCC submitting a method statement and a full technical working drawing prepared by the contractor for approval PRIOR to the work commencing

Case No: L113/2005

- 1. Restoration of Bells
- 2. Install floodlighting and power points from existing supplies to assist the restoration of the Bells

DAC Certificate Conditions: -

- 1. A time limit of 12 months

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric
 Minor Works Trees Faculty
 Recommended Not Recommended No objections
 Withdrawn
 Faculty Issued?

Date Faculty Issued 14/10/2005

Case No: L195/2008

- 1. Repairs identified by the 2006 Quinquennial Inspection
- 2. External repairs to the Belfry and Tower

DAC Certificate Conditions: -

- 1. A time limit of 12 months
- 2. That details of the works are entered in the Log Book so that a record is kept of what has been done
- 3. That the necessary protection be provided for the mortar should the temperature drop below 3 degrees

Case No: L047/2008

- 1. Removing deadwood from the crowns of 8 Lime trees
- 2. Removing suckers from the base of 8 Lime trees

DAC Certificate Conditions: -

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 21/01/2009

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Case No: L071/2009

Installation of Sound and Induction Loop System

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done
3. That the PCC ensures the contractor complies with the DAC Conditions on the installation of Sound and Induction Loop Systems (attached)

Case No: L144/2014

Following the 2012 Quinquennial Inspection, repairs comprising: -

1. General re-pointing and stonework repairs
2. Repairs to the south wall of the Chancel and helities
3. Repairs to the gullies and discharge pipes
4. Repairs to the mullions, tracery and ironwork to windows W6,W7 and W9
5. Internal plaster repairs to the Chancel

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 19/01/2010

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued 22/09/2014

Case No: L179/2015

Installation of new Noticeboard

DAC Certificate Conditions: -

1. A time limit of 12 months
2. That details of the works are entered in the Log Book so that a record is kept of what has been done

Case No:

Replacement of external wall Lantern

DAC Certificate Conditions: -

1. That details of the works are entered in the Log Book so that a record is kept of what has been done
2. That an updated Electrical Condition Report is commissioned, and submitted to the DAC Secretary, after the installation
3. That, in line with the requirement and advice of the Ecclesiastical Insurance Group, the installation

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued

Informal Minor Works Fabric

Minor Works Trees Faculty

Recommended Not Recommended No objections

Withdrawn

Faculty Issued?

Date Faculty Issued