

Form 2
(Rule 4.5)

Diocesan Advisory Committee Notification of Advice

This notification constitutes advice only and does not give you permission to carry out the works or other proposals to which it relates. A faculty must be obtained from the court before the works or proposals may lawfully be carried out.

In the Diocese of Lichfield Parish of Drayton in Hales Church of Market Drayton S. Mary

The church is listed under the Planning (Listed Buildings and Conservation Areas) Act 1990.

The listing is grade II+

At a meeting of the Diocesan Advisory Committee held on 19/10/2016, the following works or other proposals were considered:

To divide the Office (former vestry) into a smaller office and two toilets one of which will be disabled accessible.

The Committee **RECOMMENDS** the works or proposals for approval by the court:

On the proviso that the following matters were satisfactorily signed off between meetings, the Members supported this application; the following information to be supplied to the DAC Secretary:

- Details of the heritage cast iron louvre (flue vent) and of its exact positioning
- Justification for the concrete floor in the WC and the expected degree of moisture wicking; had the architect considered using limecrete?
- Confirmation that there is sufficient heat in the office area; it was noted at the time of his visit by the DAC's heating adviser that people reported this as cold and the heating provision had not increased.
- Electric heating was provided to the WC; had the architect considered extending the wet system to both to the WC and the office area?
- Light fittings in the WC are narrow beam; would these provide a sufficient level of light?
- If one was being installed, would it be worth extending the fire detection system to the whole church?

This advice does not constitute authority for carrying out the works or proposals and a faculty is required

In the opinion of the Committee the work or part of the work proposed IS not likely to affect

- the character of the church as a building of special architectural or historic interest
- the archaeological importance of the building
- archaeological remains existing within the church or its curtilage

In the opinion of the Committee rule 9.9 of the Faculty Jurisdiction Rules (publication of notice on diocesan website) applies to the works or proposals

This advice is valid for 24 months from the date given below

Kristina
Williamson

Signed _____
Secretary of the Diocesan Advisory Committee

Date: - 19/10/2016